

NRC Publications Archive **Archives des publications du CNRC**

Fire resistance tests of non-insulated walls with parallel and perpendicular orientation of gypsum board

Bwalya, A. C.

For the publisher's version, please access the DOI link below./ Pour consulter la version de l'éditeur, utilisez le lien DOI ci-dessous.

Publisher's version / Version de l'éditeur:

<https://doi.org/10.4224/20378070>

Research Report (National Research Council of Canada. Institute for Research in Construction); no. RR-188, 2005-06-27

NRC Publications Archive Record / Notice des Archives des publications du CNRC :

<https://nrc-publications.canada.ca/eng/view/object/?id=905892c2-4c23-42ad-af2e-137a1511f065>

<https://publications-cnrc.canada.ca/fra/voir/objet/?id=905892c2-4c23-42ad-af2e-137a1511f065>

Access and use of this website and the material on it are subject to the Terms and Conditions set forth at

<https://nrc-publications.canada.ca/eng/copyright>

READ THESE TERMS AND CONDITIONS CAREFULLY BEFORE USING THIS WEBSITE.

L'accès à ce site Web et l'utilisation de son contenu sont assujettis aux conditions présentées dans le site

<https://publications-cnrc.canada.ca/fra/droits>

LISEZ CES CONDITIONS ATTENTIVEMENT AVANT D'UTILISER CE SITE WEB.

Questions? Contact the NRC Publications Archive team at

PublicationsArchive-ArchivesPublications@nrc-cnrc.gc.ca. If you wish to email the authors directly, please see the first page of the publication for their contact information.

Vous avez des questions? Nous pouvons vous aider. Pour communiquer directement avec un auteur, consultez la première page de la revue dans laquelle son article a été publié afin de trouver ses coordonnées. Si vous n'arrivez pas à les repérer, communiquez avec nous à PublicationsArchive-ArchivesPublications@nrc-cnrc.gc.ca.





National Research
Council Canada

Conseil national
de recherches Canada

NRC - CNRC

Fire Resistance Tests of Non-Insulated Walls with Parallel and Perpendicular Orientation of Gypsum Board

Research Report No. 188

Date: June 27, 2005

Author: Alex C. Bwalya

Institute for Research in Construction

Fire Research Program

Abstract

This report presents the results of six fire resistance tests of non-insulated loaded and unloaded wall assemblies constructed with the gypsum wallboard applied parallel to the framing members in two of the assemblies and perpendicular to the framing in the other four assemblies. The objective of the tests was to determine the significance of the orientation of the gypsum board (parallel versus perpendicular) to the studs on the fire resistance of both loaded and unloaded walls.

The average fire resistance of unloaded walls with a parallel orientation of the gypsum boards was found to be 28 min and that of walls with perpendicular orientation was 30 min. The fire resistance of loaded wall assemblies was 23 min for parallel orientation and 26 min for perpendicular orientation of gypsum boards. These results show that the orientation of the gypsum board had a minimal effect on the fire resistance. The cracked sections of gypsum board tended to fall off earlier in the walls with gypsum boards applied parallel to the studs, resulting in slightly reduced fire resistance and a greater extent of charring.

TABLE OF CONTENTS

List of Figures	ii
1 Introduction.....	1
2 The Wall Assemblies.....	1
3 Test Facility	3
3.1 Instrumentation and Data Acquisition	3
4 Test Procedure.....	5
4.1 Failure Criteria.....	5
5 Results and Discussion	6
5.1 Extent of Charring	7
6 Summary	8
7 Acknowledgements	8
8 References	Error! Bookmark not defined.
Appendix A: Tables.....	10

LIST OF FIGURES

Figure 1. Dimensions and layout of wall assemblies (fire-exposed side shown).....	2
Figure 2. Location of thermocouples on the unexposed surface of an unloaded assembly.	
.....	4
Figure 3. Location of additional non-mandatory thermocouples inside the wall assemblies.	
.....	4
Figure 4. Deflection measurement points for full-scale wood stud loaded wall assemblies.	
.....	5

LIST OF TABLES

Table 1. Applicable standards for the wall assemblies.....	2
Table 2. Results of the fire tests.....	4
Table 3. Mean dimensions (length x width) of uncharred wood for selected stud cross-sections taken at mid-height.....	5
Table A - 1. Mass of wood frame and gypsum board	10
Table A - 2. Charring patterns	11
Table A - 3. Temperatures measured on the unexposed side of the assembly in Test 1..	12
Table A - 4. Temperatures measured inside the upper half section of the assembly in Test 1	13
Table A - 5. Temperatures measured inside the lower half section of the assembly in Test 1	14
Table A - 6. Temperatures measured on the unexposed side of the assembly in Test 2	15
Table A - 7. Temperatures measured inside the upper half section of the assembly in Test 2	16
Table A - 8. Temperatures measured inside the lower half section of the assembly in Test 2	17
Table A - 9. Temperatures measured on the unexposed side of the assembly in Test 3	18
Table A - 10. Temperatures measured inside the upper half section of the assembly in Test 3	19
Table A - 11. Temperatures measured inside the lower half section of the assembly in Test 3	20

Table A - 12. Temperatures measured on the unexposed side of the assembly in Test 4	21
Table A - 13: Temperatures measured inside the upper half section of the assembly in Test 4	22
Table A - 14. Temperatures measured inside the lower half section of the assembly in Test 4	23
Table A - 15. Temperatures measured on the unexposed side of the assembly in Test 5	24
Table A - 16. Temperatures measured inside the upper half section of the assembly in Test 5	25
Table A - 17. Temperatures measured inside the lower half section of the assembly in Test 5	26
Table A - 18. Temperatures measured on the unexposed side of the assembly in Test 6	27
Table A - 19. Temperatures measured inside the upper half section of the assembly in Test 6	28
Table A - 20. Temperatures measured inside the lower half section of the assembly in Test 6	29
Table A - 21: Deflection measurements in test 5.....	30
Table A - 22. Deflection measurements in Test 6.....	31

Fire Resistance of Non-Insulated Walls with Parallel and Perpendicular Orientation of Gypsum Board

by

Alex C. Bwalya

1 INTRODUCTION

Six full-scale standard fire-resistance tests were conducted to determine the fire resistance of non-insulated loaded and unloaded wall assemblies, which are typically used as interior partitions. Two types of assemblies were tested: the first type (Type 1) were constructed with the gypsum wallboard applied so that the joints between the boards were parallel to the vertical framing members and the second type (Type 2) were constructed with gypsum wallboard applied so that the joints were perpendicular to the vertical framing members. The objective of these tests was to study the effect of the orientation of the gypsum wallboard (parallel or perpendicular) on the fire resistance since none of the previous tests¹⁻⁴ conducted at the National Research Council (NRC) of Canada, Institute for Research in Construction (IRC) included walls with gypsum board applied perpendicular to the framing. In practice the perpendicular of gypsum boards is popular for non-fire rated walls because of the belief that horizontal joints are less conspicuous as the first joint is located below eye level at a height of 1.2 m, and the continuous horizontal joints are easier to tape than vertical ones⁵.

Measurements of the depth of the char layer were also taken for up to three studs from each wall assembly that was tested.

2 THE WALL ASSEMBLIES

Table 1 lists the governing product and application standards. The wall assemblies tested were constructed by the same workers using a single layer of 12.7 mm thick ProRoc™ (previously branded Westroc) regular lightweight gypsum board with an approximate weight per unit area of 7.8 kg/m². The gypsum board was screwed to the wood framing using *Type S* drywall screws of a length of 31.8 mm (1-1/4 in.). The framing was constructed with wood studs 38 mm x 89 mm (nominal 2 in. x 4 in.) SPF No. 1 spaced at 400 mm on centre. All the fastener heads were covered with joint compound and all the joints were covered with tape and joint compound.

The dimensions of the full-scale wall assemblies and the spacing of the fasteners are shown in Figure 1.




Figure 1. Dimensions and layout of wall assemblies (fire-exposed side shown)

The wall assemblies were mounted in a concrete frame designed for testing loaded and unloaded wall assemblies.

Table 1. Applicable standards for the wall assemblies

Item	Product/Application Standard
Wall assembly	CAN/CSA-A82.31-M91
Gypsum board	CAN/CSA-A82.27-M91 ⁶ /ASTM C 1396
Studs	CAN/CSA-0141
Nails	CSA B111
Screws	ASTM C 1002
Joint finishing materials (compound and fibre tape)	ASTM C 475

3 TEST FACILITY

The apparatus used in the tests was the vertical full-scale propane-fired wall furnace, which has been adequately described in previous NRC publications^{1,3,4}. The furnace temperature is automatically controlled using the average temperature of nine shielded chromel-alumel (Type-K) 20 gauge thermocouples, as required by the CAN/ULC-S101-M89 standard test method⁷.

The loading system consisted of a steel frame, in which the assembly was placed, and eight hydraulic jacks fitted at the top to simulate vertical structural loads.

3.1 Instrumentation and Data Acquisition

All temperatures were measured with Type-K thermocouples. In accordance with the standard method⁸, a minimum of nine shielded thermocouples was attached under insulating pads at prescribed positions on the unexposed side of the wall, as shown in Figure 2. In addition to the nine mandatory thermocouples, 46 additional thermocouples were installed — 40 at various locations inside the assembly and six on the unexposed surface, as shown in Figure 3. The additional temperature data was intended for future analytical studies.

In the case of load-bearing assemblies, deflection measurements were taken at the nine locations shown in Figure 4 using electro-mechanical gauges.




Figure 2. Location of thermocouples on the unexposed surface of an unloaded assembly.




Figure 3. Location of additional non-mandatory thermocouples inside the wall assemblies.




Figure 4. Deflection measurement points for full-scale wood stud loaded wall assemblies.

A computer-based data logging system was used to record the temperature, furnace pressure and deflection data directly to a computer hard disk at one-minute intervals.

Three video cameras were used to film the tests; one was directed at the unexposed surface and the other two at the fire exposed side.

4 TEST PROCEDURE

The tests were conducted in conformity to the CAN/ULC-S101-M89 test specification⁸, which is similar to the ASTM E119 standard⁹.

4.1 Failure Criteria

The fire resistance of non-load-bearing wall assemblies is judged by the integrity or insulation criteria. These criteria are intended to test the ability of a wall assembly to prevent a fire from spreading to adjacent rooms. Therefore, the appearance of visible cracks or fissures, which permit smoke or hot gases to penetrate the unexposed surface of the assembly, constitutes failure under the integrity criteria. According to the test specification, the temperature of the unexposed surface should not rise high enough to ignite cotton waste attached to the surface. The insulation criteria requires that the temperature of the unexposed side of the assembly, as measured by the nine mandatory thermocouples, does not experience an average

temperature increase of 140 °C above ambient and that the maximum temperature rise at any single thermocouple (single-point) on this surface does not exceed 180 °C above ambient.

In the case of load-bearing walls, an additional stability criterion also applies – the assembly must perform its load-bearing function and carry the applied loads for the duration of the test, without structural collapse. The CAN/ULC-S101-M89 limits the maximum deflection, at any one point, to 150 mm.

In all of the tests in which insulation failure occurred first, the furnace was not shut down until flames appeared on the unexposed surface so as to collect additional temperature data that will be used in future analyses.

5 RESULTS AND DISCUSSION

The fire resistance of each of the six wall assemblies is given in Table 2. The temperatures recorded during the tests are given in Tables A - 3 to A - 20 and the deflection measurements for tests 5 and 6 are given in Tables A - 21 and A - 22, respectively. The applied load in tests 5 and 6 was selected from values used in previous tests at NRC¹.

Table 2. Results of the fire tests

Test number	Wall type ¹	Applied load (kN)	Gypsum board Joint	Fire resistance (min)	Failure mode
			opening / crack formation / fall out times (min) ²		
1	1 //	-	15 / 17 / 19	28	Insulation ³
2	2 ⊥	-	15 / 18 / > 26	26	Insulation
3	2 ⊥	-	15 / 20 / 32	34	Insulation
4	2 ⊥	-	15 / 16 / 29	30	Insulation
5	1 //	68.8	14 / 16 / 18	23	Integrity
6	2 ⊥	68.8	15 / 16 / 23	26	Integrity

¹ Orientation of gypsum board: Type 1 – parallel (//); Type 2- perpendicular (⊥)

² Observed times to the nearest minute

³ Single-point insulation failure

The average fire resistance of the three unloaded Type 2 wall tests is 30 min.

Test 4 was a repeat test necessitated by the large discrepancy between the fire resistance

obtained in tests 2 and 3. This result is not significantly different from the fire resistance of 28 min, which was obtained in test 1 (Type 1 wall).

In the tests with unloaded wall assemblies (tests 1 to 4), insulation failure was a result of the rapid rise in temperature, which occurred after sections of cracked gypsum board fell off and permitted flames to enter the wall cavity. The difference in failure times is related to falling-off times of cracked pieces of gypsum board – failure is precipitated by early fall-off times.

In previous tests at NRC¹, a loaded Type 1 specimen, of identical construction and loading, achieved a fire resistance rating of 26 min. Therefore, the results of tests 5 and 6 with loaded assemblies show that the orientation of gypsum board has no significant impact on fire resistance. An examination of gypsum falling-off times for the two tests reveals that cracked sections of gypsum fell off earlier in test 5 (Type 2 wall) than in test 6 (Type 1 wall), thereby precipitating failure.

5.1 Extent of Charring

The average dimensions of uncharred wood for selected stud cross-sections taken at mid-height are given in Table 3.

Table 3. Mean dimensions (length x width) of uncharred wood for selected stud cross-sections taken at mid-height

Test #	Wall type ²	Dimensions of remaining uncharred cross section (mm) ¹		
		Stud 5	Stud 6	Stud 7
1	1 //	NA	45 x 9	78 x 30
2	2 ⊥	72 x 25	78 x 23	78 x 25
3	2 ⊥	70 x 13	64 x 17	69 x 19
4	2 ⊥	83 x 29	83 x 32	79 x 30
5	1 //	65 x 16	66 x 20	62 x 12
6	2 ⊥	82 x 28	83 x 27	79 x 22

¹Nominal dimensions of virgin studs are 89 mm x 38 mm

²Orientation of gypsum board: Type 1 – parallel (//); Type 2- perpendicular (⊥)

NA: Measurement was not taken.

The unloaded Type 1 (test 1) wall experienced the highest degree of charring, and a portion of stud 6 was completely charred. The charring patterns for selected stud cross-sections taken at mid-height are given in Table A - 2. The differences in charring rates can be attributed to the orientation of the joint between the gypsum boards and the fall-off times of cracked pieces of gypsum board. In Type 1 walls, the studs at which the joints were formed experience a greater exposure to the fire than those in Type 2 walls.

6 SUMMARY

The fire resistance of the unloaded Type 1 wall (parallel orientation) was found to be 28 min and that of Type 2 walls (perpendicular orientation) was an average of 30 min. These limited tests showed that the orientation of the gypsum board did not have a significant effect on the fire resistance of unloaded wall assemblies. However, a close examination of the charred studs revealed that the studs in Type 1 (parallel) walls experienced a greater extent of charring than Type 2 (perpendicular) walls.

The fire resistance of the loaded Type 1 wall was found to be 23 min and that of the Type 2 wall was 26 min. The fire resistance of the Type 1 wall is slightly lower because the joints between the gypsum boards opened along a stud and cracked pieces of gypsum board fell off earlier.

The failure of all of the wall assemblies was generally precipitated by the opening of the joints and cracking of the gypsum board, which is a result of shrinkage and calcination.

7 ACKNOWLEDGEMENTS

The author acknowledges the industriousness of the technical staff at the FR program in setting up and running the tests. Deserving special mention in this regard are: Jocelyn Henrie, Roch Monette, John Latour, Patrice Leroux, Richard Rombough and Yves Séguin.

8 REFERENCES

1. Sultan, M. A., Lougheed, G. D., Denham, E. M. A., Monette, R. C., and MacLaurin, J. W., "Temperature Measurements in Full-Scale Fire Resistance Tests on Non-Insulated Regular Gypsum Board Wall Assemblies", NRC Internal Report, Vol. No. 674, December 199.
2. Alfawakhiri, F. and Sultan, M. A., "Fire Resistance of Load-bearing Steel-Stud Walls Protected with Gypsum Board: a Review", Fire Technology, Vol. 35(4), November 1999, pp.308-335
3. Sultan, M. A., "Correlation of Small- and Full-Scale Fire Resistance on Insulated and Non-

Insulated Lightweight Frame Gypsum Board Wall Assemblies,", Interflam '96, 7th International Fire Science and Engineering Conference, St. John's College, Cambridge, England , April 1996, pp.933-937

4. Sultan, M. A., "Effect of Insulation in the Wall Cavity on the Fire Resistance Rating of Full-Scale Asymmetrical (1x2) Gypsum Board Protected Wall Assemblies", International Conference on Fire Research and Engineering, Orlando, Florida, USA, September 1995, pp.545-550
5. Canada Mortgage and Housing Corporation, C., Canadian Wood-Frame House Construction, CMHC, Ottawa, Ontario, Canada, 1997.
6. CAN/CSA-A82.27-M91, "Gypsum Board-Building Materials and Products", Canadian General Standards Board, Ottawa, Ontario, Canada, 1986
7. Sultan, M. A., Bénichou, N., and Min, B. Y., "Heat Exposure in Fire Resistance Furnaces: Full-Scale Vs. Intermediate-Scale", Fire and Materials, San Francisco, U.S.A, January 2003
8. CAN/ULC-S101-M89, "Standard Methods of Fire Endurance Tests of Building Construction and Materials", Canadian General Standards Board, Ottawa, Ontario, Canada, 1989
9. ASTM E119-00a, "Standard Test Method for Fire Tests of Building Construction and Materials", ASTM International, West Conshohocken, PA, USA, 2000.

APPENDIX A: TABLES

Table A - 1. Mass of wood frame and gypsum board.

Test Number	Wall Type	Mass of gypsum board (kg)	Mass of wood frame (kg)	Mean wood moisture content (%)	Total mass (kg)
1	1 //	NA	NA	NA	NA
2	2 ⊥	211.0	69.6	9.2	280.6
3	2 ⊥	208.8	69.2	9.0	278.0
4	2 ⊥	NA	NA	NA	NA
5	1 //	199.0	NA	NA	NA
6	2 ⊥	206.8	65.2	10.5	272.0

NA: Data not available

Orientation of gypsum board: Type 1 – parallel (//); Type 2- perpendicular (⊥)

Table A - 2. Charring patterns


Test #	Stud no. 5	Stud no. 6	Stud no. 7
1	-		
2			
3			
4			
5			
6			

Table A - 3. Temperatures measured on the unexposed side of the assembly in Test 1

Time (min)	S101	Favg	Thermocouple number on unexposed side														
			1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0	20	24	22	23	21	21	23	23	22	21	22	20	21	19	22	20	21
1	124	41	22	23	21	21	23	23	22	21	22	21	21	19	22	20	21
2	227	183	22	23	21	21	23	23	22	20	22	21	21	19	22	20	21
3	331	346	25	26	23	23	27	26	24	22	24	23	22	20	24	22	23
4	434	372	31	35	28	29	35	35	29	25	29	29	23	21	30	26	28
5	538	510	36	42	33	33	42	42	33	29	34	33	24	22	34	29	33
6	571	587	41	48	38	38	47	48	37	33	39	35	26	23	37	32	35
7	604	577	47	54	43	43	53	54	42	37	44	37	27	24	40	34	39
8	638	646	51	58	47	47	57	58	46	41	48	39	29	25	41	36	41
9	671	653	55	61	50	51	61	62	49	45	52	40	30	27	43	38	41
10	704	712	59	64	54	54	64	65	53	48	56	42	31	28	44	40	42
11	715	719	62	66	57	57	66	67	56	52	59	44	32	29	44	41	44
12	726	721	65	68	60	60	68	69	59	55	62	45	33	30	45	42	45
13	738	742	67	70	62	63	69	71	61	58	65	45	35	32	47	43	47
14	749	746	69	71	64	65	71	72	63	61	67	46	35	32	47	45	48
15	760	752	72	74	67	68	72	73	66	63	69	47	37	33	48	46	48
16	767	769	74	76	69	70	74	75	69	66	71	49	38	35	48	48	50
17	774	779	80	81	72	72	78	80	72	69	73	51	38	36	53	49	55
18	781	781	84	84	77	79	82	84	78	72	77	57	41	37	55	54	58
19	788	781	88	88	82	83	85	87	82	79	81	60	42	39	60	59	58
20	795	796	93	92	84	86	88	93	84	84	83	61	45	41	61	60	60
21	800	804	97	96	87	88	92	97	87	87	85	63	49	43	62	61	62
22	805	801	101	101	90	92	97	103	92	91	87	64	50	45	66	62	63
23	811	813	105	107	93	97	101	110	96	96	89	65	50	47	74	64	63
24	816	820	109	113	97	101	105	116	100	99	93	65	51	48	81	65	64
25	821	815	112	118	101	104	109	122	104	103	97	67	53	48	86	67	67
26	825	831	115	122	104	108	112	126	107	105	101	68	55	48	93	69	71
27	830	830	118	127	107	110	115	137	110	107	106	71	57	50	103	71	71
28	834	834	120	135	110	114	118	193	112	109	111	77	59	53	140	72	75

Favg = Mean furnace temperature (°C); S101 = CAN/ULC-S101 standard temperature (°C)

Table A - 4. Temperatures measured inside the upper half section of the assembly in Test 1

Time (min)	S101	Favg	Thermocouple number inside upper half section (even numbers)																			
			16	18	20	22	24	26	28	30	32	34	36	38	40	42	44	46	72	74	76	78
0	20	24	23	23	24	24	24	24	24	23	23	23	21	24	23	23	23	23	n/a	n/a	n/a	n/a
1	124	41	24	24	24	24	30	29	29	23	23	23	21	29	28	24	24	24	n/a	n/a	n/a	n/a
2	227	183	68	69	63	69	99	87	89	24	23	25	26	79	78	73	64	69	25	25	24	22
3	331	346	70	71	68	70	93	86	85	25	24	27	27	79	77	69	66	69	30	28	27	24
4	434	372	65	65	63	64	89	79	78	26	25	29	26	76	75	64	61	64	34	30	29	25
5	538	510	72	73	72	72	99	90	87	29	27	30	30	88	85	73	70	72	37	32	31	26
6	571	587	76	76	75	75	101	92	88	31	30	32	30	99	95	76	73	75	41	36	34	28
7	604	577	74	75	74	73	105	96	93	34	33	35	30	106	101	78	73	77	44	38	37	30
8	638	646	78	79	79	77	111	102	101	36	36	38	31	111	105	83	78	82	47	41	39	32
9	671	653	80	83	83	78	120	106	105	40	39	41	33	115	109	86	82	85	50	43	42	34
10	704	712	83	86	86	81	133	110	109	43	43	44	35	119	112	89	84	88	53	46	45	36
11	715	719	87	90	89	83	155	114	113	46	46	47	37	123	117	91	87	91	56	48	47	39
12	726	721	92	93	91	86	177	120	118	50	49	51	38	133	128	95	89	95	59	51	49	41
13	738	742	103	103	99	93	213	127	127	58	53	54	39	168	167	106	97	108	61	53	52	43
14	749	746	121	120	116	112	257	155	153	68	56	58	41	219	212	128	114	135	64	55	54	46
15	760	752	149	150	141	140	327	206	197	70	60	63	44	264	254	161	145	172	67	58	57	49
16	767	769	186	184	174	179	394	254	237	66	64	70	48	310	303	198	179	207	72	61	61	52
17	774	779	216	217	200	208	536	296	276	76	67	70	52	334	329	222	197	227	80	67	67	55
18	781	781	241	238	222	237	652	326	309	77	68	71	56	337	390	249	226	282	90	73	74	60
19	788	781	263	521	497	434	701	751	638	83	71	76	63	881	509	274	517	417	101	81	82	67
20	795	796	282	726	705	787	790	833	807	128	114	224	70	856	531	303	809	564	111	93	90	79
21	800	804	310	758	765	814	782	811	812	277	297	565	78	842	546	352	818	582	119	109	98	89
22	805	801	358	775	819	833	794	840	836	400	503	694	87	864	575	414	847	617	128	126	107	97
23	811	813	408	869	859	843	873	903	838	801	715	767	99	882	608	467	870	646	141	146	117	103
24	816	820	447	805	833	809	807	851	807	773	763	763	105	842	636	501	834	651	163	171	125	110
25	821	815	489	850	847	821	849	866	823	839	794	787	118	856	896	544	846	841	180	188	134	117
26	825	831	521	831	893	825	832	877	867	819	832	811	158	865	821	579	904	824	214	208	146	125
27	830	830	631	830	884	807	870	861	824	823	826	780	262	856	797	684	877	795	521	232	250	131
28	834	834	877	878	883	826	869	922	781	896	910	798	333	921	800	882	900	819	852	815	304	137

Favg = Mean furnace temperature (°C); S101 = CAN/ULC-S101 standard temperature (°C)

Table A - 5. Temperatures measured inside the lower half section of the assembly in Test 1

Time (min)	S101	Favg	Thermocouple number inside lower half section (odd numbers)																			
			17	19	21	23	25	27	29	31	33	35	37	39	41	43	45	47	73	75	77	79
0	20	24	22	22	22	22	22	22	22	21	21	21	22	22	21	21	21	21	n/a	n/a	n/a	n/a
1	124	41	22	22	22	22	26	26	27	21	21	21	22	24	22	22	22	25	n/a	n/a	n/a	n/a
2	227	183	63	57	55	54	99	80	91	21	21	21	59	48	64	68	57	76	29	31	25	23
3	331	346	60	58	58	58	93	84	86	22	21	22	59	47	61	61	58	71	36	42	33	26
4	434	372	55	54	54	53	89	77	79	23	22	24	55	46	55	56	53	68	38	43	34	27
5	538	510	65	63	62	61	98	90	90	24	23	26	63	53	65	66	63	80	41	47	37	29
6	571	587	67	66	65	64	102	92	92	25	24	28	66	59	67	67	65	89	44	52	40	32
7	604	577	66	66	65	63	107	96	94	27	26	31	66	68	66	68	66	96	47	54	42	34
8	638	646	71	70	70	68	125	104	101	29	27	34	70	80	72	76	73	102	49	57	45	37
9	671	653	75	72	73	69	146	108	106	32	29	36	72	90	77	80	78	106	52	60	47	39
10	704	712	79	74	77	73	182	114	112	34	31	40	75	92	80	84	82	110	54	62	50	42
11	715	719	82	78	81	75	226	121	117	37	34	44	78	92	84	88	86	116	57	65	53	44
12	726	721	86	82	83	77	261	125	123	39	36	48	79	86	85	89	88	121	59	67	56	47
13	738	742	93	87	87	79	262	133	130	42	39	52	82	106	92	96	93	140	61	69	59	49
14	749	746	108	96	97	82	278	149	146	46	41	58	86	148	107	115	108	183	63	70	62	51
15	760	752	130	111	116	88	339	188	190	49	44	67	96	140	134	139	133	222	66	72	65	55
16	767	769	167	137	143	107	372	224	229	51	47	72	119	154	172	174	167	266	72	80	69	59
17	774	779	212	172	176	134	451	260	264	55	51	74	155	313	212	215	197	339	81	94	76	62
18	781	781	251	198	197	165	605	300	301	59	54	75	193	368	228	246	217	382	90	107	80	69
19	788	781	273	225	226	194	660	321	344	65	58	77	226	293	253	268	245	391	101	122	87	78
20	795	796	287	252	250	226	700	354	382	76	63	80	249	300	270	293	268	390	112	152	94	91
21	800	804	301	273	272	259	646	380	428	80	68	84	272	379	289	321	290	405	124	182	103	104
22	805	801	322	296	296	301	660	404	470	83	72	85	294	399	310	344	313	420	137	213	111	112
23	811	813	349	324	317	330	664	430	494	84	77	87	318	415	337	380	336	436	153	256	119	117
24	816	820	388	346	340	362	648	456	521	85	81	88	356	440	359	425	363	451	169	305	126	124
25	821	815	472	370	365	417	685	482	543	87	85	90	401	461	387	493	389	472	185	342	134	130
26	825	831	543	401	400	513	699	499	670	91	89	132	488	492	411	549	427	482	202	393	145	138

Favg = Mean furnace temperature (°C); S101 = CAN/ULC-S101 standard temperature (°C)

Table A - 6. Temperatures measured on the unexposed side of the assembly in Test 2

Time (min)	S101	Favg	Thermocouple number on unexposed side														
			1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0	20	21.5	21.3	21.5	21.2	21.3	21.5	21.5	21.4	21.2	21.5	21.3	21.5	21.3	21.5	21.3	21.5
1	124	37.6	21.4	21.5	21.2	21.3	21.5	21.5	21.4	21.2	21.5	21.3	21.5	21.3	21.5	21.3	21.5
2	227	233.2	21.5	21.7	21.3	21.4	21.7	21.6	21.5	21.2	21.6	21.3	21.6	21.4	21.7	21.4	21.6
3	331	384.9	24.8	25.4	23.5	23.6	25.6	26.0	23.9	22.6	25.0	24.3	22.1	21.7	25.3	23.2	24.7
4	434	394.4	30.9	32.4	27.5	27.4	32.5	34.2	28.5	25.6	30.9	28.5	23.6	22.9	30.8	26.1	29.7
5	538	536.7	35.7	37.9	30.9	30.5	37.6	40.3	32.2	28.3	35.5	30.6	25.6	24.2	33.7	28.0	32.4
6	571	591.8	40.3	43.0	34.3	33.7	42.5	46.0	35.6	30.9	39.8	33.0	27.4	25.3	36.5	30.2	35.0
7	604	574.7	45.0	48.2	38.0	37.1	47.5	51.6	39.2	34.0	44.5	33.7	30.0	27.6	38.8	32.3	37.4
8	638	639.8	48.4	51.9	41.1	39.9	50.9	55.1	41.9	36.8	47.9	35.1	31.9	28.7	40.2	33.6	38.5
9	671	652.8	51.4	55.0	44.0	42.5	53.9	58.0	44.5	39.7	50.9	35.4	34.1	31.0	41.6	35.3	39.8
10	704	700.3	54.1	57.6	46.6	44.9	56.4	60.5	46.8	42.4	53.5	36.8	36.1	31.4	42.7	35.2	40.9
11	715	723.6	56.6	60.0	49.2	47.2	58.7	62.7	49.0	45.2	56.1	37.5	38.2	33.7	43.3	38.0	41.9
12	726	707.3	58.6	61.9	51.5	49.4	60.7	64.4	51.0	47.9	58.2	38.2	40.2	35.5	44.2	39.4	42.8
13	738	751.3	60.5	63.7	53.6	51.5	62.3	65.8	52.8	50.3	60.1	38.6	41.6	37.0	45.6	40.1	44.1
14	749	732.1	62.1	65.7	55.6	53.4	63.8	67.0	54.4	52.0	61.7	39.7	42.2	37.7	46.1	41.0	44.9
15	760	770.7	64.7	68.5	58.3	56.1	66.2	68.8	56.5	53.0	63.9	41.1	42.3	37.6	48.1	42.3	46.8
16	767	762.4	67.6	71.5	61.7	59.6	68.9	71.2	59.4	54.1	66.8	43.9	42.6	37.0	49.9	42.5	48.5
17	774	779.0	72.0	77.4	65.3	63.0	72.9	75.1	63.2	56.6	70.0	45.2	43.2	39.6	53.5	45.2	53.1
18	781	773.4	79.4	87.8	70.6	68.6	80.4	81.8	69.6	59.5	75.6	52.2	44.7	40.1	58.4	47.7	58.5
19	788	794.8	83.6	88.6	79.0	77.5	83.9	84.9	76.8	61.5	80.5	56.0	47.4	40.8	62.3	53.5	65.6
20	795	796.1	85.9	90.9	83.0	80.5	86.1	86.8	80.5	66.7	82.9	55.8	50.7	43.6	64.0	54.2	67.7
21	800	789.0	88.4	99.8	85.2	82.6	89.4	90.1	82.3	75.7	84.3	57.9	52.7	47.5	63.4	55.0	67.6
22	805	800.2	92.6	110.7	89.0	86.7	94.2	94.6	83.5	81.6	85.9	57.0	55.1	50.2	63.4	55.1	68.2
23	811	821.2	97.1	118.7	93.6	91.1	99.2	98.9	85.5	86.2	89.2	56.9	57.8	53.1	64.4	55.8	69.6
24	816	815.8	101.3	124.3	98.0	94.9	103.6	103.5	89.3	90.6	93.6	58.2	60.1	53.7	66.7	59.0	73.0
25	821	809.7	104.9	130.4	102.7	98.1	107.4	107.4	93.6	94.5	98.1	60.1	61.7	55.8	71.0	59.5	82.1
26	825	829.5	107.7	142.4	106.2	100.8	110.6	110.8	97.6	97.7	102.1	61.7	62.3	58.1	74.3	61.8	87.7
27	830	832.5	110.2	205.8	109.8	104.1	113.2	113.5	101.3	102.2	105.5	62.2	63.0	59.2	76.7	61.8	90.2
28	834	823.3	112.6	299.8	113.2	106.5	115.6	115.6	104.5	105.8	108.3	63.5	64.4	61.9	79.1	66.0	93.8

Favg = Mean furnace temperature (°C); S101 = CAN/ULC-S101 standard temperature (°C)

Table A - 7. Temperatures measured inside the upper half section of the assembly in Test 2

Time (min)	S101	Favg	Thermocouple number inside upper half section (even numbers)																			
			16	18	20	22	24	26	28	30	32	34	36	38	40	42	44	46	72	74	76	78
0	20	22	22	22	22	22	22	22	22	22	22	22	22	22	21	21	21	21	21	21	21	21
1	124	38	22	22	22	22	26	26	25	22	22	22	25	25	30	22	22	22	22	21	21	21
2	227	233	68	71	69	65	88	90	83	23	23	34	83	84	86	67	73	64	40	38	45	24
3	331	385	63	67	65	62	80	79	75	34	42	50	76	76	78	63	67	63	45	43	46	27
4	434	394	57	63	60	59	74	74	71	37	43	48	71	71	72	58	61	58	46	43	44	28
5	538	537	66	71	70	67	86	88	82	40	46	53	83	85	85	67	71	66	49	48	50	30
6	571	592	68	73	70	70	86	85	78	49	59	62	88	93	96	69	70	68	50	52	53	32
7	604	575	65	70	68	68	92	91	84	52	59	61	100	102	105	70	70	67	50	52	53	32
8	638	640	70	74	72	71	99	98	91	56	63	64	106	108	112	76	81	71	52	54	56	33
9	671	653	70	76	72	73	104	103	95	60	66	67	110	112	116	79	85	76	54	56	57	35
10	704	700	73	80	75	75	108	109	102	63	70	70	114	116	120	82	88	79	57	59	60	36
11	715	724	74	82	76	76	113	113	107	66	72	72	119	120	125	85	92	81	58	60	61	37
12	726	707	76	85	78	77	117	117	111	68	73	74	125	125	133	88	95	84	60	62	63	39
13	738	751	78	89	79	79	119	116	114	64	73	74	140	140	170	93	99	90	62	63	64	40
14	749	732	86	102	84	83	152	148	136	63	74	74	192	193	229	113	121	109	64	65	68	41
15	760	771	102	120	100	108	187	187	176	63	75	74	233	235	277	139	148	138	66	67	70	43
16	767	762	142	157	132	144	231	234	216	65	77	76	286	286	345	182	190	185	71	74	76	46
17	774	779	184	191	176	186	267	265	255	63	79	79	350	345	392	227	232	226	85	88	94	50
18	781	773	220	276	207	221	323	329	298	65	76	80	387	375	570	274	264	440	106	105	116	56
19	788	795	247	430	240	302	370	361	343	70	80	81	407	405	664	303	309	668	125	121	140	62
20	795	796	272	508	269	391	420	388	381	76	83	84	430	431	705	327	338	710	143	137	160	69
21	800	789	293	553	297	481	465	410	415	84	85	85	446	449	709	348	358	723	158	151	175	77
22	805	800	326	620	324	623	505	439	432	94	89	88	468	476	710	384	389	771	178	162	191	88
23	811	821	355	665	355	638	554	472	454	118	90	98	493	490	714	419	409	783	203	174	207	99
24	816	816	379	658	367	633	591	501	494	127	91	104	504	492	706	436	415	767	226	186	226	107
25	821	810	401	641	385	629	624	522	518	370	93	108	518	504	686	457	431	772	245	201	213	113
26	825	830	415	669	386	637	635	521	535	353	93	115	526	500	686	470	438	794	264	219	240	118

Favg = Mean furnace temperature (°C); S101 = CAN/ULC-S101 standard temperature (°C)

Table A - 8. Temperatures measured inside the lower half section of the assembly in Test 2

Time (min)	S101	Favg	Thermocouple number inside lower half section (odd numbers)																		
			17	19	21	23	25	27	29	31	33	35	37	39	41	43	45	47	73	75	77
0	20	22	21	21	21	21	22	21	21	21	22	22	21	22	21	21	21	21	21	21	21
1	124	38	22	22	21	21	25	24	24	21	22	22	27	23	23	21	21	21	21	21	21
2	227	233	57	57	58	44	77	82	74	21	22	22	76	78	78	57	58	55	28	41	25
3	331	385	50	55	53	48	73	75	68	21	22	24	68	70	71	52	54	52	33	44	29
4	434	394	47	51	50	46	68	69	64	21	24	26	63	64	66	48	50	49	34	43	30
5	538	537	57	60	59	53	80	83	75	21	25	28	77	79	79	57	60	57	36	48	32
6	571	592	57	62	59	57	85	83	72	22	27	32	84	81	86	58	60	59	39	51	35
7	604	575	55	60	58	55	89	87	78	22	30	36	91	91	96	61	62	59	41	50	36
8	638	640	59	64	63	59	95	94	85	22	33	40	98	98	102	66	68	65	43	53	38
9	671	653	61	66	66	61	99	98	91	22	36	43	101	101	106	68	70	68	45	53	40
10	704	700	65	70	69	63	104	104	98	22	39	47	106	106	110	72	74	71	48	54	42
11	715	724	66	72	71	65	108	109	104	22	43	50	110	110	114	74	77	74	49	55	44
12	726	707	68	75	74	67	113	114	111	22	46	54	116	115	121	77	79	76	51	55	45
13	738	751	70	76	74	68	120	119	119	22	47	56	128	120	130	79	80	79	53	57	46
14	749	732	76	81	77	72	139	127	137	22	48	56	170	136	174	90	87	89	55	59	48
15	760	771	85	91	85	75	178	161	176	22	52	58	199	178	213	107	101	105	57	60	50
16	767	762	104	109	100	80	214	196	212	22	59	63	235	215	254	136	126	135	60	65	52
17	774	779	131	132	134	99	252	227	252	23	61	65	280	248	301	169	159	169	67	64	55
18	781	773	174	176	170	138	325	271	290	23	57	67	387	300	382	221	196	207	79	73	60
19	788	795	215	209	218	209	413	357	404	23	59	74	384	391	408	256	243	239	92	82	70
20	795	796	229	225	244	227	489	442	451	23	71	78	361	404	412	263	267	263	104	92	80
21	800	789	234	239	251	246	528	542	529	23	76	81	353	378	403	263	271	276	115	101	91
22	805	800	237	252	254	267	540	617	626	23	79	81	348	360	397	265	268	285	126	111	101
23	811	821	243	269	255	289	564	640	663	24	79	81	347	352	400	266	269	299	138	120	111
24	816	816	250	457	259	312	597	738	665	24	78	81	350	351	416	272	275	326	149	130	122
25	821	810	258	564	268	369	638	758	700	24	78	81	351	352	479	278	283	406	159	139	135
26	825	830	341	599	641	406	647	737	623	24	83	97	355	457	521	289	441	478	170	148	150
																					118

Favg = Mean furnace temperature (°C); S101 = CAN/ULC-S101 standard temperature (°C)

Table A - 9. Temperatures measured on the unexposed side of the assembly in Test 3

Time (min)	S101	Favg	Thermocouple number on unexposed side														
			1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0	20	21	20	21	20	20	20	21	20	20	20	21	21	21	21	21	21
1	124	39	20	21	20	20	20	21	20	20	20	21	21	21	21	21	21
2	227	213	21	21	20	20	21	21	21	20	21	21	21	21	21	21	21
3	331	362	24	24	23	23	25	25	23	22	24	25	22	21	25	21	25
4	434	379	30	32	28	28	33	34	27	26	31	31	24	22	31	21	31
5	538	533	35	38	32	32	40	41	31	29	37	36	26	23	34	21	35
6	571	574	41	45	37	37	47	48	35	33	42	40	28	24	37	21	39
7	604	583	47	51	42	42	53	55	39	37	48	43	30	25	40	21	41
8	638	634	51	55	46	46	58	59	42	41	52	45	32	26	41	21	43
9	671	663	55	59	50	50	61	63	45	45	56	47	35	27	43	21	44
10	704	707	59	62	53	54	65	65	48	49	59	49	37	28	44	21	45
11	715	715	62	65	57	57	67	68	51	52	62	51	39	29	46	21	47
12	726	732	65	67	60	60	70	70	54	56	65	53	42	31	47	21	48
13	738	732	67	68	62	63	71	71	57	59	67	54	44	32	48	21	49
14	749	738	69	70	63	65	73	72	60	61	68	55	47	34	50	21	51
15	760	764	72	73	64	67	74	74	63	62	70	56	47	34	51	21	52
16	767	769	74	77	66	69	76	76	66	63	72	57	49	35	53	21	53
17	774	765	80	82	69	73	81	80	70	65	75	61	51	38	59	21	59
18	781	773	84	84	77	82	85	84	74	73	81	67	53	39	61	21	62
19	788	783	86	84	84	86	87	85	78	82	84	68	55	41	62	21	63
20	795	797	88	87	86	86	88	87	80	82	85	69	58	43	64	21	64
21	800	807	92	91	86	86	92	92	81	84	86	69	60	45	64	21	65
22	805	800	97	95	89	91	97	97	82	89	90	71	63	47	64	21	65
23	811	801	102	100	93	97	102	102	84	94	95	72	64	48	66	21	67
24	816	818	106	105	97	101	107	107	86	98	99	75	65	50	67	21	68
25	821	829	109	109	100	105	111	111	90	101	104	78	66	49	70	21	72
26	825	820	112	112	104	108	114	114	94	104	108	82	67	51	75	22	76
27	830	823	114	115	108	111	116	116	97	108	111	86	68	53	78	22	80
28	834	839	116	117	111	114	119	118	100	112	114	89	68	56	82	22	81
29	839	843	118	119	114	116	120	120	103	116	116	91	68	57	84	22	81
30	843	846	121	121	117	119	122	121	106	120	119	94	70	58	87	22	84
31	847	851	123	125	120	122	124	123	109	123	122	96	71	59	91	22	87
32	851	854	125	130	124	125	126	125	112	127	125	99	73	59	99	22	88
33	854	864	128	138	128	129	129	128	114	132	129	102	74	60	122	22	92
34	858	856	133	187	133	136	133	134	117	139	133	105	78	62	193	22	95

Favg = Mean furnace temperature (°C); S101 = CAN/ULC-S101 standard temperature (°C)

Table A - 10. Temperatures measured inside the upper half section of the assembly in Test 3

Time (min)	S101	Favg	Thermocouple number inside upper half section (even numbers)																			
			16	18	20	22	24	26	28	30	32	34	36	38	40	42	44	46	72	74	76	78
0	20	21	21	21	21	21	21	21	21	21	21	21	21	21	21	20	21	21	21	21	20	20
1	124	39	21	21	21	21	26	26	26	21	21	21	24	22	25	21	27	21	21	21	20	20
2	227	213	68	66	69	68	80	80	87	21	22	21	80	69	82	73	86	68	30	26	27	21
3	331	362	68	67	68	67	76	74	80	26	43	22	76	66	75	70	78	66	37	32	34	24
4	434	379	63	62	63	62	73	71	76	30	42	23	73	62	72	65	74	62	38	33	35	25
5	538	533	73	71	73	73	85	84	89	31	41	27	83	73	83	75	87	72	39	32	38	27
6	571	574	75	73	75	74	82	79	88	40	58	29	89	74	91	76	94	73	41	33	41	29
7	604	583	74	72	73	73	84	81	91	44	58	34	97	73	101	75	107	73	43	35	40	31
8	638	634	78	76	78	78	91	85	96	49	63	38	106	77	109	78	115	77	45	37	41	34
9	671	663	79	78	79	79	95	96	100	54	67	44	111	78	114	82	120	82	48	40	43	36
10	704	707	82	81	81	84	101	101	105	59	71	50	115	81	118	89	123	86	50	42	46	36
11	715	715	83	83	83	85	109	106	110	64	74	56	118	86	124	91	128	88	53	44	48	37
12	726	732	84	86	83	87	113	115	115	68	74	67	123	89	134	94	135	91	55	46	50	39
13	738	732	84	91	84	91	119	124	121	67	74	71	136	92	176	101	151	104	57	48	52	41
14	749	738	90	98	90	100	158	154	146	64	74	66	169	102	230	117	211	130	59	50	53	43
15	760	764	107	123	104	126	201	198	184	67	77	63	221	123	294	147	261	176	61	52	55	46
16	767	769	154	178	144	171	241	241	223	66	79	63	292	166	347	201	324	212	64	55	57	47
17	774	765	186	208	177	194	268	279	258	68	80	65	333	200	366	231	362	237	71	59	61	49
18	781	773	207	235	196	214	288	293	274	70	81	65	358	222	373	252	376	262	79	64	69	51
19	788	783	230	281	222	239	316	301	297	71	80	70	386	251	415	279	370	303	88	70	80	53
20	795	797	256	324	254	272	345	328	327	73	79	74	411	284	479	313	386	357	102	77	92	56
21	800	807	281	364	287	306	375	355	361	77	80	77	436	319	518	341	411	402	116	84	105	61
22	805	800	305	400	317	337	403	388	391	81	84	80	457	351	550	369	436	441	131	91	117	69
23	811	801	333	438	354	368	434	414	418	85	87	84	475	387	571	398	457	472	144	102	126	77
24	816	818	360	478	391	397	467	435	445	87	89	87	492	418	589	420	483	501	158	112	135	84
25	821	829	382	523	407	407	504	452	461	92	90	88	508	433	586	438	497	515	172	122	145	90
26	825	820	402	556	406	410	527	465	470	116	91	89	521	435	582	457	496	522	185	132	158	95
27	830	823	414	575	409	421	539	476	476	119	91	89	527	442	602	467	497	521	197	142	229	99
28	834	839	452	565	428	438	538	494	493	123	93	90	582	468	636	476	507	540	208	152	230	102
29	839	843	503	631	460	465	555	543	517	197	96	93	577	514	640	495	524	572	220	164	256	106
30	843	846	506	712	499	503	646	583	553	471	103	95	573	545	664	515	557	618	235	176	282	111
31	847	851	564	748	567	584	737	684	644	623	121	100	610	607	706	532	627	687	265	190	307	116
32	851	854	640	801	779	820	791	798	870	772	195	505	694	778	817	621	783	740	330	217	351	122
33	854	864	834	811	849	872	838	856	880	838	868	840	823	843	807	849	860	808	837	823	501	130
34	858	856	869	823	804	826	849	866	823	872	863	818	813	802	796	793	854	776	780	878	700	138

Favg = Mean furnace temperature (°C); S101 = CAN/ULC-S101 standard temperature (°C)

Table A - 11. Temperatures measured inside the lower half section of the assembly in Test 3

Time (min)	S101	Favg	Thermocouple number inside lower half section (odd numbers)																			
			17	19	21	23	25	27	29	31	33	35	37	39	41	43	45	47	73	75	77	79
0	20	21	21	21	21	21	21	21	21	21	21	21	21	21	20	20	20	20	21	20	20	20
1	124	39	21	21	21	21	25	24	26	21	21	21	26	24	24	21	21	21	21	21	20	20
2	227	213	59	55	57	56	76	79	81	21	21	21	78	77	79	60	55	61	24	23	29	21
3	331	362	57	56	55	54	73	76	76	21	21	21	71	70	71	57	55	57	29	27	36	22
4	434	379	53	52	52	52	68	71	71	22	22	22	69	66	67	54	52	53	31	28	37	23
5	538	533	63	63	63	63	79	87	83	23	23	23	82	80	81	64	62	65	33	29	41	24
6	571	574	64	64	64	64	78	85	82	24	24	24	91	85	86	65	64	65	37	32	45	26
7	604	583	64	64	64	65	80	87	85	26	26	26	100	96	97	66	64	65	40	33	46	28
8	638	634	69	69	69	70	85	92	85	28	28	27	107	104	105	75	72	74	43	36	47	30
9	671	663	71	71	71	72	87	94	87	30	31	30	111	109	109	78	76	77	45	38	48	32
10	704	707	74	75	74	77	92	98	90	32	33	32	116	113	114	82	81	82	48	40	50	34
11	715	715	76	76	76	79	95	103	95	34	36	34	121	116	118	85	83	84	50	42	52	36
12	726	732	78	78	78	83	100	109	100	37	38	37	126	120	122	88	86	85	53	44	53	39
13	738	732	77	80	78	83	107	113	108	39	41	41	135	126	128	88	87	85	55	46	55	41
14	749	738	79	84	79	89	126	120	138	42	45	44	178	145	152	93	91	88	57	48	57	44
15	760	764	85	90	85	104	168	155	180	44	49	46	224	198	201	109	108	102	59	50	58	46
16	767	769	100	112	96	136	202	201	212	47	54	48	287	250	254	143	140	134	61	53	60	47
17	774	765	151	165	134	185	257	245	238	50	63	54	397	329	351	208	196	188	65	56	65	49
18	781	773	196	205	180	218	298	278	273	53	65	57	435	400	411	265	246	244	71	60	73	51
19	788	783	227	235	216	244	334	318	306	58	67	60	429	418	434	288	288	283	77	66	83	53
20	795	797	248	254	244	258	369	384	341	63	71	64	404	425	425	293	310	298	87	71	92	56
21	800	807	261	269	259	274	403	487	373	67	77	69	403	391	404	299	306	296	98	79	102	61
22	805	800	273	288	268	286	435	636	400	71	81	75	402	378	393	312	305	296	106	86	115	70
23	811	801	282	304	274	296	464	686	423	75	82	79	395	368	384	313	301	293	114	94	127	77
24	816	818	288	314	279	304	492	707	446	78	83	82	391	366	381	315	302	294	121	102	136	84
25	821	829	296	338	289	317	520	720	472	80	82	85	395	369	384	321	309	301	128	110	147	91
26	825	820	308	486	390	335	565	614	501	91	86	84	404	615	437	334	507	330	134	118	161	98
27	830	823	419	506	464	364	572	575	518	117	89	87	598	642	578	594	599	549	141	125	240	103
28	834	839	542	515	527	390	587	584	535	114	92	92	621	688	652	591	641	652	148	132	231	109
29	839	843	594	528	564	412	609	595	549	115	93	98	634	692	658	598	660	679	156	140	254	112
30	843	846	577	541	580	457	612	616	564	127	96	100	660	691	675	647	686	682	165	149	283	115
31	847	851	625	557	597	502	627	630	584	141	102	101	663	701	686	634	689	690	178	174	304	119
32	851	854	668	593	634	535	627	644	597	172	111	103	694	720	703	667	707	705	224	210	343	124
33	854	864	801	789	819	809	849	859	966	309	154	113	834	861	779	838	821	753	848	807	458	130
34	858	856	823	831	825	853	859	903	835	782	603	135	792	883	779	800	828	763	794	831	664	131

Favg = Mean furnace temperature (°C); S101 = CAN/ULC-S101 standard temperature (°C)

Table A - 12. Temperatures measured on the unexposed side of the assembly in Test 4

Time (min)	S101	Favg	Thermocouple number on unexposed side														
			1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0	20	19	20	20	20	19	20	20	20	19	20	20	21	20	21	20	20
1	124	36	20	20	20	19	20	20	20	19	20	20	21	20	21	20	20
2	227	195	20	20	20	20	20	21	20	19	20	20	21	20	21	20	20
3	331	354	24	24	22	23	26	26	23	21	22	20	23	20	25	21	24
4	434	371	32	33	28	29	35	36	29	25	28	22	27	21	33	25	31
5	538	498	38	40	33	34	41	43	35	29	33	23	28	22	37	28	33
6	571	587	43	46	37	38	47	49	40	32	37	24	29	23	40	30	35
7	604	574	48	51	42	43	53	55	45	36	42	25	30	24	43	33	37
8	638	645	52	55	46	46	56	59	49	40	46	27	31	25	44	34	38
9	671	655	56	58	50	50	59	62	52	44	49	28	33	26	45	36	39
10	704	712	59	61	53	53	62	64	55	48	52	30	33	27	47	38	40
11	715	708	62	63	56	56	64	66	58	52	54	31	35	28	48	39	41
12	726	727	64	65	59	59	66	68	61	55	57	32	36	30	49	40	42
13	738	736	66	67	62	61	68	70	64	58	59	34	37	31	50	42	43
14	749	741	69	69	64	63	70	72	66	61	61	35	37	32	51	43	44
15	760	766	71	72	67	66	72	73	68	63	63	37	38	33	51	44	46
16	767	765	75	77	69	68	75	78	71	66	65	38	38	34	55	45	48
17	774	765	81	81	73	70	80	82	76	69	67	39	39	36	60	46	53
18	781	777	84	86	79	75	84	86	81	72	73	40	42	37	66	51	58
19	788	791	87	88	83	81	87	90	83	79	78	43	44	40	67	54	59
20	795	798	91	92	86	84	92	93	85	83	81	45	47	43	65	56	59
21	800	803	96	98	91	88	97	99	87	85	83	48	49	44	67	59	60
22	805	797	101	103	95	92	101	104	89	88	85	50	50	46	67	59	60
23	811	805	105	109	100	97	105	109	93	92	89	53	52	48	71	59	61
24	816	817	109	113	104	102	109	113	97	96	93	56	54	46	77	61	62
25	821	818	112	116	107	106	112	116	101	100	96	57	55	48	83	62	64
26	825	827	115	120	110	110	114	119	105	103	100	60	55	51	87	64	69
27	830	831	118	126	112	114	117	121	109	106	104	60	56	52	91	65	72
28	834	826	120	140	114	118	119	124	113	109	107	63	57	52	97	69	73
29	839	837	123	184	116	121	121	129	117	111	110	63	56	55	104	72	75
30	843	847	125	246	118	124	123	136	120	113	114	65	61	51	118	76	78
31	847	854	131	321	120	127	127	164	122	115	117	67	63	54	166	76	80
32	851	853	141	417	122	134	132	262	125	117	119	68	65	52	195	78	84
33	854	847	196	490	124	144	144	396	129	119	122	69	69	52	213	81	87
34	858	854	302	547	129	188	201	517	133	121	125	71	74	54	221	83	91

Table A - 13: Temperatures measured inside the upper half section of the assembly in Test 4

Time (min)	S101	Favg	Thermocouple number inside upper half section (even numbers)																			
			16	18	20	22	24	26	28	30	32	34	36	38	40	42	44	46	72	74	76	78
0	20	20	***	21	21	21	20	21	21	21	21	21	20	21	21	21	21	21	20	20	20	20
1	124	124	***	21	21	21	26	25	25	21	21	21	25	23	27	21	21	22	20	20	20	20
2	227	227	***	72	72	71	87	88	92	55	40	28	89	83	89	71	73	79	40	35	44	22
3	331	331	***	72	72	72	84	84	86	37	31	26	81	79	84	69	72	76	52	46	53	26
4	434	434	***	65	65	65	78	78	80	35	30	28	75	74	77	63	66	69	52	46	51	27
5	538	538	***	72	72	72	85	88	89	43	34	31	85	83	87	69	72	75	54	49	55	29
6	571	571	***	76	75	75	95	98	95	41	34	33	94	92	100	73	76	78	54	54	60	31
7	604	604	***	74	74	74	99	99	98	41	37	36	105	100	108	72	74	85	55	55	59	33
8	638	638	***	76	77	76	104	105	104	46	40	39	110	107	112	74	78	90	57	57	61	36
9	671	671	***	79	79	79	110	110	108	49	43	42	115	112	118	77	84	94	60	59	62	39
10	704	704	***	81	81	81	115	117	113	56	48	45	119	117	124	82	88	100	62	61	64	42
11	715	715	***	84	84	83	125	138	118	60	51	49	125	122	134	86	93	108	64	64	66	44
12	726	726	***	88	88	86	160	175	125	62	53	52	133	137	169	92	99	121	67	66	68	47
13	738	738	***	97	99	102	205	217	165	63	54	56	170	182	222	103	114	151	69	67	70	50
14	749	749	***	124	121	126	244	261	215	69	58	61	230	234	269	131	144	192	71	69	72	52
15	760	760	***	156	156	157	268	332	273	65	69	65	280	292	315	169	188	233	74	74	75	52
16	767	767	***	192	191	190	289	359	316	65	66	76	335	342	368	199	218	277	83	86	87	53
17	774	774	***	282	235	241	343	398	345	73	67	71	378	382	533	235	265	674	97	103	111	55
18	781	781	***	602	302	418	434	472	436	78	81	73	396	480	585	276	475	643	116	120	137	60
19	788	788	***	664	390	500	562	544	544	88	88	88	420	565	639	321	610	715	137	139	162	67
20	795	795	***	694	462	578	652	578	611	90	91	91	449	615	662	366	646	721	160	159	186	74
21	800	800	***	708	520	610	683	601	640	92	92	93	467	639	682	396	676	696	185	181	209	83
22	805	805	***	680	542	589	657	615	630	93	94	94	490	646	718	427	668	735	212	203	233	95
23	811	811	***	700	588	620	677	643	643	93	101	99	505	668	740	456	695	723	238	226	259	106
24	816	816	***	715	601	621	695	652	650	95	113	117	527	684	741	484	720	736	263	250	288	115
25	821	821	***	727	606	614	716	704	685	108	127	269	535	693	764	495	722	695	326	272	317	123
26	825	825	***	737	615	654	723	764	699	142	143	487	549	694	772	516	709	709	414	292	347	129
27	830	830	***	736	603	711	733	746	729	205	158	630	570	664	782	545	655	727	469	312	366	139
28	834	834	***	736	592	749	719	772	730	320	168	721	589	685	782	581	673	748	483	331	387	207
29	839	839	***	765	601	755	732	808	735	404	180	746	617	722	792	613	698	779	516	351	410	243
30	843	843	***	826	787	764	831	894	704	464	473	755	668	832	858	649	832	758	574	390	592	273
31	847	847	***	771	828	763	769	840	727	416	786	770	673	861	905	660	809	745	597	446	662	314
32	851	851	***	820	833	758	827	833	730	437	802	799	728	877	914	725	805	773	635	862	657	337
33	854	854	***	825	873	767	858	827	764	510	829	775	717	818	898	730	831	782	704	776	699	357
34	858	858	***	822	872	760	848	838	765	601	824	758	719	800	919	743	836	780	777	824	748	380

Table A - 14. Temperatures measured inside the lower half section of the assembly in Test 4

Time (min)	S101	Favg	Thermocouple number inside lower half section (odd numbers)																		
			17	19	21	23	25	27	29	31	33	35	37	39	41	43	45	47	73	75	77
0	20	19	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
1	124	36	20	20	20	20	24	26	30	20	20	20	24	23	23	20	20	20	20	20	20
2	227	195	63	51	56	62	78	78	82	22	26	27	77	81	79	56	62	68	29	25	31
3	331	354	59	57	58	61	78	75	79	22	23	25	74	79	75	56	59	62	36	32	39
4	434	371	54	53	54	56	71	69	72	22	24	26	69	71	69	52	55	57	39	33	39
5	538	498	63	59	61	64	82	82	84	24	26	28	81	86	82	60	63	65	41	36	42
6	571	587	66	65	66	68	89	91	94	25	27	29	94	96	93	64	66	68	46	39	47
7	604	574	65	64	65	68	95	95	100	27	28	31	101	106	101	63	65	67	48	42	49
8	638	645	69	68	69	73	99	101	105	29	31	34	107	113	107	67	69	75	51	44	52
9	671	655	72	70	71	76	104	105	111	31	33	36	112	118	112	69	71	80	53	47	55
10	704	712	75	73	74	81	108	108	115	34	37	39	115	121	116	72	75	84	56	49	57
11	715	708	78	75	77	84	111	113	121	37	41	44	120	126	121	76	81	87	58	52	60
12	726	727	80	77	79	88	114	118	127	39	42	45	126	131	128	78	83	90	61	54	62
13	738	736	82	79	82	94	121	121	143	41	44	51	146	144	152	81	88	97	63	56	65
14	749	741	85	82	89	111	152	149	184	44	48	60	194	193	204	89	98	113	65	59	67
15	760	766	92	90	101	137	187	188	221	46	64	66	228	245	244	103	118	142	69	61	69
16	767	765	121	114	133	182	226	221	271	49	60	75	268	297	297	128	154	184	77	67	74
17	774	765	151	147	162	213	257	254	319	53	61	73	324	351	360	161	186	218	88	77	87
18	781	777	190	188	201	278	292	301	299	58	71	78	406	397	401	210	220	270	100	87	105
19	788	791	225	226	237	311	430	334	342	67	78	80	405	418	416	235	248	316	114	99	123
20	795	798	236	256	260	338	499	357	374	74	82	82	371	434	419	240	271	330	130	112	139
21	800	803	239	282	279	366	549	402	409	76	83	84	361	441	430	244	293	351	145	128	157
22	805	797	247	313	301	395	571	435	473	77	86	86	359	441	446	251	313	374	161	142	171
23	811	805	308	349	320	424	554	475	490	79	87	87	399	440	466	294	328	401	175	156	191
24	816	817	363	386	344	452	549	521	522	80	89	90	437	450	484	330	350	426	192	170	214
25	821	818	426	427	367	479	550	540	555	83	91	93	582	463	506	463	374	454	265	185	244
26	825	827	476	462	398	498	553	527	620	87	95	96	634	480	549	547	402	505	270	201	270
27	830	831	511	500	455	524	567	524	631	90	99	102	666	504	540	594	439	506	305	216	285
28	834	826	564	541	469	548	621	537	598	95	105	109	723	535	545	653	482	516	376	216	293
29	839	837	621	541	477	560	625	549	610	99	110	129	701	543	568	654	489	575	507	234	315
30	843	847	633	643	498	631	725	571	628	359	115	142	686	547	595	650	503	653	613	274	721
31	847	854	609	643	520	668	708	593	650	308	123	213	692	566	623	656	534	696	607	372	731
32	851	853	617	702	529	708	757	607	668	393	134	296	696	586	627	660	567	724	617	436	632
33	854	847	631	768	552	751	823	650	695	1071	167	275	709	613	642	674	592	715	718	725	643
34	858	854	663	783	573	766	836	671	709	1009	212	317	751	643	715	695	638	797	761	781	643

Table A - 15. Temperatures measured on the unexposed side of the assembly in Test 5

Time (min)	S101	Favg	Thermocouple number on unexposed side														
			1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0	20	23	21	22	21	21	22	22	21	21	21	21	21	19	21	20	21
1	124	47	21	22	21	21	22	22	21	21	21	21	21	19	21	20	21
2	227	205	21	22	21	21	22	22	21	21	21	21	21	19	21	20	21
3	331	333	25	28	25	23	25	27	24	23	23	26	23	20	26	22	27
4	434	373	31	37	31	28	33	36	30	27	29	33	25	21	32	26	35
5	538	540	37	44	36	33	39	43	34	30	34	38	27	22	34	29	40
6	571	550	42	52	42	38	46	50	39	34	39	43	29	24	37	32	44
7	604	610	48	58	47	43	53	56	45	38	43	48	30	25	39	35	49
8	638	621	52	62	51	48	58	60	49	42	48	50	32	26	41	35	51
9	671	679	56	65	55	52	62	63	53	46	52	53	34	27	42	37	53
10	704	692	59	67	58	55	65	66	57	50	55	55	36	28	43	39	54
11	715	721	62	69	61	59	68	68	60	54	58	56	37	30	44	40	56
12	726	721	64	70	63	61	70	70	63	57	61	57	39	31	45	41	57
13	738	733	67	72	65	64	72	71	66	59	63	58	40	32	46	42	57
14	749	751	69	73	67	66	73	72	68	62	65	60	42	33	47	43	60
15	760	761	72	75	69	68	75	74	71	65	67	61	45	34	49	44	61
16	767	761	77	80	72	70	77	78	74	68	69	63	46	36	54	47	67
17	774	770	81	83	76	73	81	82	79	71	73	68	47	36	56	49	71
18	781	784	84	87	81	77	84	83	83	76	78	72	50	37	63	53	73
19	788	795	86	91	84	81	86	85	89	81	81	74	57	39	64	56	79
20	795	793	91	96	87	84	90	90	91	84	88	80	62	41	64	56	79
21	800	804	96	105	90	87	92	95	91	86	89	79	65	41	65	55	80
22	805	803	100	115	95	89	93	100	93	91	92	79	67	44	67	56	94
23	811	813	105	122	99	91	99	105	99	95	100	83	69	42	73	57	107
24	816	779	110	130	103	94	110	109	108	100	109	75	67	42	61	58	104

Table A - 16. Temperatures measured inside the upper half section of the assembly in Test 5

Time (min)	S101	Favg	Thermocouple number inside upper half section (even numbers)																			
			16	18	20	22	24	26	28	30	32	34	36	38	40	42	44	46	72	74	76	78
0	20	23	22	22	22	23	23	23	22	22	22	23	23	23	23	22	22	22	22	22	21	21
1	124	47	23	24	23	23	28	32	26	22	24	22	32	33	37	24	25	25	22	22	22	21
2	227	205	74	75	68	69	100	89	89	41	78	22	84	84	86	77	75	77	41	31	56	29
3	331	333	72	72	67	69	93	80	85	31	72	24	81	78	78	71	70	71	49	37	56	35
4	434	373	68	68	64	65	97	78	79	31	69	25	79	78	78	68	68	69	50	39	55	36
5	538	540	77	77	73	75	98	84	88	32	78	28	90	88	90	77	77	78	57	44	64	42
6	571	550	77	77	74	75	99	86	87	33	77	32	100	98	102	76	76	78	59	47	63	44
7	604	610	78	78	76	76	105	88	91	36	78	36	109	108	110	78	85	84	60	47	64	47
8	638	621	80	79	78	78	109	91	98	39	80	40	116	113	115	85	90	88	61	48	65	50
9	671	679	81	81	79	80	118	94	103	42	80	44	118	117	119	90	93	91	62	51	67	53
10	704	692	83	83	81	82	137	101	106	47	82	48	123	121	123	93	96	93	63	52	67	57
11	715	721	84	85	82	83	156	111	109	51	88	51	128	127	129	96	99	97	65	55	67	60
12	726	721	84	89	83	86	153	119	114	53	97	54	139	142	168	100	105	110	67	57	68	62
13	738	733	86	102	83	92	186	137	121	72	111	58	185	192	222	115	128	136	68	59	70	64
14	749	751	104	131	96	106	224	178	143	68	134	61	232	240	270	141	160	173	69	62	72	67
15	760	761	141	170	128	134	289	220	194	65	170	65	281	290	324	180	203	214	72	64	75	69
16	767	761	178	197	165	169	408	271	238	70	192	72	329	331	318	218	233	239	78	69	82	72
17	774	770	204	228	187	192	723	299	283	69	217	75	362	351	354	244	255	283	88	76	96	74
18	781	784	223	653	226	225	793	608	439	324	499	75	377	406	928	266	307	816	97	87	114	77
19	788	795	271	781	308	330	812	773	848	813	639	73	432	443	824	353	366	855	113	101	150	79
20	795	793	880	776	386	419	850	823	842	868	727	76	915	485	826	916	428	859	688	123	184	87
21	800	804	858	799	414	470	840	823	710	865	752	83	901	550	847	873	483	862	749	160	218	99
22	805	803	865	832	805	871	875	874	875	894	842	713	909	832	889	879	824	877	822	236	256	116
23	811	813	859	837	809	852	860	821	846	870	817	628	893	812	882	853	807	873	823	349	321	130
24	816	779	765	738	778	695	806	799	732	732	773	636	738	776	721	706	761	743	693	417	394	214

Table A - 17. Temperatures measured inside the lower half section of the assembly in Test 5

Time (min)	S101	Favg	Thermocouple number inside lower half section (odd numbers)																			
			17	19	21	23	25	27	29	31	33	35	37	39	41	43	45	47	73	75	77	79
0	20	23	21	21	21	21	22	22	22	21	21	21	22	22	21	21	21	21	22	22	21	21
1	124	47	22	22	22	22	26	27	30	21	21	21	30	27	26	22	21	21	22	22	21	21
2	227	205	66	65	60	61	98	87	86	28	24	22	77	74	74	68	59	66	29	28	27	24
3	331	333	61	60	57	58	91	79	80	26	24	23	74	73	67	61	55	60	36	33	31	28
4	434	373	58	57	55	56	95	76	76	26	24	24	72	71	68	59	54	57	38	35	33	29
5	538	540	69	68	64	67	98	87	87	28	25	26	84	83	79	70	63	68	43	39	37	33
6	571	550	68	67	64	66	95	85	90	29	27	27	94	92	88	68	63	67	46	42	40	35
7	604	610	70	69	67	68	96	90	96	31	29	29	104	102	95	70	66	69	49	45	42	38
8	638	621	73	71	70	71	96	93	101	33	31	31	111	108	101	77	69	71	51	48	45	40
9	671	679	75	74	72	74	97	97	104	37	33	33	114	112	105	82	75	75	53	50	48	43
10	704	692	78	76	76	77	105	100	108	43	35	35	117	116	109	85	79	80	55	52	50	46
11	715	721	80	77	78	80	119	104	111	46	37	37	121	121	113	88	82	81	56	53	53	49
12	726	721	81	80	80	83	145	111	116	45	39	40	126	128	122	91	85	84	57	55	55	51
13	738	733	83	85	83	86	160	116	124	55	56	42	142	146	149	95	90	91	59	56	57	53
14	749	751	89	97	94	95	198	129	151	54	64	45	186	196	184	110	104	106	60	58	59	56
15	760	761	98	117	120	115	238	166	189	54	73	48	229	242	228	133	134	136	62	61	62	58
16	767	761	121	147	166	148	276	206	225	75	78	50	277	294	299	172	174	177	65	65	67	60
17	774	770	159	176	188	176	320	235	262	78	77	54	328	335	371	210	200	203	71	72	74	63
18	781	784	184	210	214	203	380	273	270	80	81	58	353	375	399	236	225	235	80	81	83	66
19	788	795	210	246	235	230	386	295	288	80	81	62	336	402	437	272	256	274	89	93	96	68
20	795	793	263	286	261	255	403	321	313	79	82	66	365	414	452	322	294	307	768	111	110	72
21	800	804	298	317	286	279	434	342	337	81	84	72	398	427	458	363	314	336	780	140	124	78
22	805	803	339	352	314	310	480	376	366	81	84	77	424	443	476	393	334	372	802	228	140	87
23	811	813	382	389	345	333	505	406	394	84	86	83	459	460	490	436	358	404	784	343	156	97
24	816	779	572	720	742	594	886	666	719	114	102	114	759	768	418	783	581	598	644	508	320	119

Table A - 18. Temperatures measured on the unexposed side of the assembly in Test 6

Time (min)	S101	Favg	Thermocouple number on unexposed side														
			1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0	20	25	24	25	24	24	25	25	24	24	24	26	27	25	27	25	25
1	124	44	24	25	24	24	25	25	24	24	24	26	27	25	27	25	25
2	227	216	25	25	24	24	25	25	25	24	25	26	27	25	27	25	26
3	331	378	30	31	28	28	30	31	27	27	29	30	28	26	32	28	30
4	434	389	38	40	35	35	39	42	33	32	36	35	29	26	39	32	36
5	538	522	43	47	39	40	45	49	37	36	41	37	31	28	43	34	39
6	571	606	49	52	43	44	51	55	41	40	46	39	33	29	46	36	40
7	604	565	54	57	48	49	56	60	46	44	51	41	34	30	49	38	42
8	638	647	57	60	51	52	59	63	49	48	54	43	36	31	49	41	44
9	671	641	60	63	54	55	62	65	52	51	57	44	37	33	51	42	45
10	704	715	62	65	57	58	64	67	55	55	60	44	38	34	52	43	45
11	715	696	65	67	60	61	66	69	58	58	62	45	39	35	53	43	46
12	726	740	67	69	62	63	68	70	60	61	64	46	40	36	54	44	47
13	738	718	68	70	64	65	69	71	62	63	66	47	43	38	54	46	48
14	749	762	70	73	66	67	70	72	64	64	67	44	45	41	55	45	50
15	760	747	72	75	69	68	72	73	66	64	69	46	46	42	57	47	50
16	767	775	75	79	71	70	74	77	68	66	71	47	47	43	58	50	53
17	774	774	81	84	74	73	77	83	71	68	73	50	48	45	63	51	57
18	781	771	84	91	80	79	82	86	76	69	76	53	49	46	70	57	62
19	788	797	86	89	84	83	86	88	81	74	81	56	52	49	71	58	64
20	795	795	88	91	86	85	90	87	86	80	83	56	58	51	69	59	65
21	800	789	90	99	91	88	90	94	88	84	85	56	62	53	70	60	64
22	805	800	95	107	96	93	95	103	89	88	86	56	64	55	71	61	65
23	811	816	100	114	100	98	101	111	91	92	89	56	65	56	76	63	66
24	816	826	104	119	104	102	107	117	97	97	92	60	67	58	82	66	67
25	821	828	108	122	108	105	112	122	108	101	96	63	67	60	88	68	72
26	825	825	112	127	113	108	116	125	117	104	100	63	68	61	94	70	79

Table A - 19. Temperatures measured inside the upper half section of the assembly in Test 6

Time (min)	S101	Favg	Thermocouple number inside upper half section (even numbers)																			
			16	18	20	22	24	26	28	30	32	34	36	38	40	42	44	46	72	74	76	78
0	20	25	25	25	25	25	24	25	25	25	25	25	25	25	25	25	25	25	24	24	24	24
1	124	44	25	25	25	26	33	33	32	26	25	25	30	31	37	26	26	27	24	24	24	24
2	227	216	76	73	73	75	87	90	84	30	27	51	88	87	87	79	74	80	28	32	36	27
3	331	378	73	72	72	73	80	81	78	29	28	38	81	81	80	75	72	76	38	39	41	31
4	434	389	67	66	66	67	74	74	71	30	30	37	75	75	77	69	66	70	41	40	42	32
5	538	522	74	72	72	73	87	88	81	32	32	42	86	86	88	75	72	76	44	43	45	34
6	571	606	77	76	76	76	89	87	84	34	34	41	96	97	101	78	76	79	47	47	49	36
7	604	565	74	74	74	74	90	88	83	36	36	43	107	107	110	75	74	83	50	48	49	38
8	638	647	77	76	76	78	96	90	94	38	39	45	113	112	114	83	76	88	52	50	50	40
9	671	641	79	78	79	84	99	94	99	41	42	47	117	116	119	88	77	92	55	52	52	43
10	704	715	80	80	80	85	103	97	103	43	45	54	119	120	123	90	82	96	57	54	54	45
11	715	696	82	82	82	88	108	107	106	45	48	60	125	125	129	94	86	100	59	56	56	48
12	726	740	83	83	82	91	111	108	109	51	50	59	132	133	146	97	88	107	61	58	58	50
13	738	718	84	84	85	103	119	124	124	59	69	61	155	163	203	108	98	132	63	60	60	52
14	749	762	93	92	91	120	143	159	156	57	63	75	209	221	253	131	117	168	65	62	62	55
15	760	747	110	118	119	149	185	201	190	57	61	73	259	277	323	166	152	218	67	64	63	57
16	767	775	153	165	157	185	219	238	213	60	64	70	305	327	366	205	197	259	71	67	66	59
17	774	774	195	208	186	214	259	279	238	61	69	72	350	370	502	236	222	455	80	74	74	62
18	781	771	228	341	270	289	288	336	282	65	71	77	385	439	670	272	356	679	92	83	86	66
19	788	797	422	492	422	431	436	415	418	80	78	86	519	547	711	559	499	688	100	95	97	72
20	795	795	557	571	466	512	523	466	469	92	83	90	575	588	714	577	540	696	105	108	113	80
21	800	789	583	624	510	558	620	520	535	131	88	91	583	611	764	548	569	784	113	122	129	89
22	805	800	584	690	539	590	721	568	558	372	92	93	581	623	753	542	581	753	144	134	147	97
23	811	816	635	673	559	616	670	603	578	347	96	95	653	623	741	560	582	682	178	147	170	104
24	816	826	663	672	787	816	671	902	835	362	124	123	679	849	742	584	832	693	215	161	201	112
25	821	828	691	691	788	843	693	875	833	403	187	222	711	829	813	612	811	833	245	176	299	118
26	825	825	703	694	769	785	698	868	803	443	254	280	722	798	802	620	787	823	261	194	429	122

Table A - 20. Temperatures measured inside the lower half section of the assembly in Test 6

Time (min)	S101	Favg	Thermocouple number inside lower half section (odd numbers)																		
			17	19	21	23	25	27	29	31	33	35	37	39	41	43	45	47	73	75	77
0	20	25	24	24	24	24	24	24	24	25	24	24	24	24	24	25	24	24	24	24	24
1	124	44	25	25	25	25	29	32	25	25	24	24	33	25	29	25	29	25	24	24	24
2	227	216	69	68	69	69	80	85	62	25	25	50	84	69	80	67	84	64	31	28	36
3	331	378	63	64	63	64	77	79	64	25	25	35	76	63	73	62	78	62	37	33	43
4	434	389	59	59	59	60	72	72	60	26	26	34	72	59	70	58	72	58	38	34	44
5	538	522	66	65	67	66	81	81	65	28	27	39	86	66	81	65	86	64	41	36	47
6	571	606	63	70	69	69	86	83	70	29	29	38	99	69	92	68	98	68	44	39	52
7	604	565	65	68	68	68	88	81	69	31	30	38	106	68	99	67	107	68	47	41	53
8	638	647	69	71	72	72	91	87	72	33	32	40	110	72	105	73	111	71	49	44	55
9	671	641	71	73	74	74	92	87	75	35	34	42	115	79	109	77	116	74	51	46	58
10	704	715	75	76	76	77	94	89	77	38	37	50	118	82	112	80	119	75	54	48	59
11	715	696	78	78	79	80	95	92	80	40	39	57	124	86	117	83	124	78	56	51	60
12	726	740	78	79	79	82	104	93	81	44	41	54	133	88	124	85	131	79	58	53	60
13	738	718	79	80	79	83	119	108	83	48	46	55	173	90	154	89	152	81	60	55	61
14	749	762	80	83	81	88	152	149	88	48	48	72	215	99	189	99	203	83	62	57	63
15	760	747	82	93	88	98	196	184	100	50	50	69	259	120	232	119	249	88	63	59	69
16	767	775	96	112	108	132	227	214	134	53	52	65	288	151	278	148	282	109	66	62	68
17	774	774	141	159	143	180	270	250	201	57	53	72	365	186	341	184	340	143	71	67	73
18	781	771	190	207	187	219	321	314	252	64	63	77	405	234	353	220	357	178	78	75	83
19	788	797	216	235	211	248	383	391	275	66	70	81	406	259	400	238	379	214	88	84	95
20	795	795	241	256	230	276	408	441	314	68	74	82	400	271	423	256	374	254	109	94	114
21	800	789	260	279	240	297	443	473	341	72	78	84	388	277	452	269	366	345	128	106	132
22	805	800	267	317	247	317	484	499	366	74	80	84	383	279	468	274	358	359	147	118	150
23	811	816	280	541	256	340	524	539	397	78	83	84	390	287	483	284	358	372	166	128	173
24	816	826	300	535	272	370	543	578	425	82	84	84	409	296	531	305	364	467	185	138	204
25	821	828	326	531	296	456	550	608	432	84	86	87	435	320	599	331	383	477	201	144	325
26	825	825	356	559	320	487	565	610	642	87	88	91	463	349	662	363	409	565	220	151	462

Table A - 21: Deflection measurements in Test 5

Time	Dfl¹1	Dfl2	Dfl3	Dfl4	Dfl5	Dfl6	Dfl7	Dfl8	Dfl9
min	cm	cm	cm	cm	cm	cm	cm	cm	cm
0	0.03	-0.05	-0.07	---	-0.02	-0.06	-0.05	-0.11	-0.07
1	-0.01	-0.06	-0.04	---	-0.05	-0.08	-0.05	-0.11	-0.08
2	-0.01	-0.06	-0.08	---	-0.05	-0.06	-0.04	-0.12	-0.09
3	-0.02	-0.05	-0.04	---	-0.06	-0.08	-0.06	-0.09	-0.09
4	-0.02	-0.06	-0.03	---	-0.06	-0.04	-0.06	-0.09	-0.06
5	-0.02	-0.06	-0.03	---	-0.06	-0.06	-0.06	-0.10	-0.06
6	-0.01	-0.06	-0.01	---	-0.06	-0.03	-0.06	-0.10	-0.06
7	-0.01	-0.07	-0.01	---	-0.05	-0.02	-0.06	-0.10	-0.05
8	-0.01	-0.06	-0.01	---	-0.05	0.00	-0.06	-0.10	-0.03
9	0.00	-0.06	0.01	---	-0.04	0.01	-0.05	-0.09	-0.02
10	-0.02	-0.07	0.03	---	-0.06	0.03	-0.07	-0.09	0.00
11	-0.01	-0.06	0.02	---	-0.05	0.04	-0.07	-0.06	0.00
12	-0.01	-0.04	0.06	---	-0.04	0.06	-0.06	-0.06	0.02
13	-0.01	-0.03	0.04	---	-0.03	0.09	-0.09	-0.04	0.04
14	-0.01	0.00	0.07	---	-0.02	0.12	-0.09	-0.01	0.05
15	-0.03	0.02	0.11	---	0.00	0.13	-0.06	0.00	0.07
16	0.01	0.05	0.18	---	0.08	0.22	-0.06	0.04	0.12
17	0.07	0.09	0.25	---	0.17	0.32	-0.06	0.12	0.19
18	0.17	0.18	0.35	---	0.27	0.44	0.00	0.19	0.25
19	0.30	0.31	0.54	---	0.49	0.62	0.06	0.31	0.35
20	0.49	0.60	0.80	---	0.87	0.97	0.19	0.54	0.52
21	0.91	1.04	1.27	---	1.47	1.46	0.37	0.91	0.78
22	1.92	2.14	2.20	---	3.00	2.52	0.94	1.78	1.31
23	5.99	6.57	7.02	---	9.05	8.35	4.37	5.33	4.48
24	10.93	15.96	20.70	---	21.97	23.60	8.69	11.54	11.53

¹ Dfln: deflection

Table A - 22. Deflection measurements in Test 6.

Time	DFL-01	DFL-02	DFL-03	DFL-04	DFL-05	DFL-06	DFL-07	DFL-08	DFL-09
min.	cm								
0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1	-0.03	-0.06	-0.08	-0.12	-0.09	-0.11	-0.08	-0.08	-0.06
2	-0.04	-0.06	-0.05	-0.07	-0.06	-0.06	-0.06	-0.04	-0.06
3	0.00	-0.06	0.00	0.01	-0.03	0.00	0.00	-0.02	-0.03
4	0.03	-0.03	0.03	0.04	0.00	0.03	0.03	-0.02	0.00
5	0.03	-0.05	0.03	0.03	-0.04	0.03	0.03	-0.04	0.00
6	0.03	-0.05	0.03	0.05	-0.06	0.03	0.03	-0.04	0.00
7	0.05	-0.05	0.06	0.08	-0.04	0.06	0.05	-0.03	0.02
8	0.05	-0.06	0.06	0.08	-0.05	0.06	0.05	-0.04	0.02
9	0.08	-0.05	0.08	0.12	-0.03	0.07	0.06	-0.03	0.03
10	0.09	-0.05	0.09	0.12	-0.03	0.08	0.08	-0.03	0.03
11	0.11	-0.05	0.09	0.14	-0.03	0.09	0.09	-0.02	0.03
12	0.11	-0.05	0.11	0.16	-0.02	0.11	0.09	-0.02	0.04
13	0.13	-0.05	0.14	0.18	-0.03	0.12	0.12	-0.02	0.06
14	0.15	-0.04	0.18	0.20	0.00	0.17	0.14	0.00	0.07
15	0.20	0.00	0.24	0.28	0.03	0.23	0.18	0.04	0.11
16	0.28	0.06	0.32	0.38	0.15	0.34	0.26	0.09	0.14
17	0.36	0.15	0.41	0.51	0.26	0.46	0.34	0.17	0.20
18	0.51	0.28	0.55	0.67	0.41	0.60	0.47	0.28	0.29
19	0.68	0.47	0.75	0.91	0.67	0.80	0.62	0.43	0.41
20	0.89	0.73	1.04	1.20	1.02	1.15	0.82	0.67	0.61
21	1.17	1.08	1.45	1.57	1.46	1.58	1.03	0.96	0.87
22	1.62	1.57	2.00	2.10	2.11	2.21	1.35	1.36	1.23
23	2.27	2.29	2.69	2.84	2.99	3.04	1.76	1.93	1.71
24	3.09	3.27	3.56	3.85	4.23	4.08	2.35	2.68	2.34
25	4.31	4.76	4.86	5.38	5.93	5.75	3.23	3.73	3.30
26	7.20	7.94	8.44	8.79	9.39	9.84	5.18	5.79	5.70